



MICRO REPORT

ETHICAL CO-OP
16 FIR STREET
OBSERVATORY
7925

ATTENTION: IAN GILFILLAN

DATE: 13/07/11
DATE RECEIVED: 11/07/11
DATE TESTED: 11-13/07/11

REQ NO: CT 70059/11

PAGE 1 OF 1

SAMPLE TYPE: WATER
METHOD NO: SWJM 35; 45; 48

SAMPLE TYPE	TEST TYPE	BACT.COUNT CFU/100ml
Water		
Newlands spring	TMA	10/ml
	Coliforms	2
	<i>Escherichia coli</i>	No Growth

Specifications as per SANS 241-1: 2011 (Edition 1)

TMA: ≤1 000 cfu/ml
Total coliforms: ≤10 cfu/100 ml
E.coli or Faecal coliforms: ≤Not detected /100ml

FAHIEMA PALEKER
SENIOR MICROBIOLOGIST

BRENDA DU TOIT
LABORATORY MANAGER